

TEST CERTIFICATE

Issued to: Schneider Electric FZE
P.O. Box: 17192
Dubai
United Arab Emirates

For the product: Low-voltage switchgear and controlgear assembly

Trade name: Schneider Electric

Type/Model: Powerline Plus - 630A MDB / SMDB

Ratings: In 630 A, Icw 50 kA - 3 s, Icc 50 kA at 415 V (incoming MCCB), Icc 50 kA at 415 V (outgoing NSX MCCBs), Ue 415 V, Ui 690 V, Uimp 6 kV, for more details see annex

Manufactured by: Schneider Electric FZE
P.O. Box: 17192
Dubai
United Arab Emirates

Subject: Type test

Requirements: IEC 61439-2:2011

Cluses 10.2.2, 10.2.3, 10.3 - 10.5, 10.9, 10.10.2.3.5, 10.11, 10.13

Remarks: -


This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report number 2144037.05-INC, dated 8 December, 2011.

examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attention does not include an assessment of the manufacturer's production. The responsibility of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 8 December, 2011

Number: 2144037.104

DEKRA Certification B.V.



H.L. Schendstok

Certification Manager

© Integral publication of the certificate and adjoining reports is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V., Utrechtseweg 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 352 5800
www.dekra-certification.com Company registration 09085396